



**WAGNER-MEINERT inc.**  
Engineers - Contractors

7617 Freedom Way  
Fort Wayne, Indiana 46818

Phone 219-489-7555  
Fax 219-489-7473

DATE: July 1, 1999

MEMO: Office  
Field

RE: REFRIGERATION PIPING COLOR CODE

This is intended to be a recommended color scheme for painting non-insulated piping, when the customer does not have a specific color scheme of their own.

PIPE DESIGNATION

RUST-O-LEUM BRAND  
INDUSTRIAL ENAMEL

HIGH STAGE DISCHARGE

SAFETY RED #964

LOW STAGE DISCHARGE

SAFETY RED #964

HIGH PRESSURE LIQUID

SAFETY ORANGE #956

CONDENSED LIQUID DRAIN

SAFETY ORANGE #956

THERMOSYPHON SUPPLY & RETURN

SAFETY ORANGE #956

CONDENSER WATER SUPPLY & RETURN

SAFETY GREEN #933

RELIEF PIPING

NAVY GRAY #975

OIL POTS

NAVY GRAY #975

VESSELS

NAVY GRAY #975

MISCELLANEOUS

NAVY GRAY #975

070199vii